



Type Approval - Electrical

Approval Number	EL 00004
Manufacturer	Olex Australia Pty Limited
Manufacturing Plant	207 Sunshine Road, Tottenham, Victoria, Australia
Product Description	Olex Marketing Code XNNP23RW001 – 1 Conductor 120 mm ² stranded compacted plain annealed copper, semi-conductive conductor screen (0.3 mm min wall), 19/33 kV TR-XLPE insulated (8.0mm nom wall), Strippolex insulation screen (0.6 mm min wall), copper wire screened (area 90 mm ² min suitable for 13.5 kA for 1 sec fault level), PVC (5V-90) sheathed (2.0 mm min wall), HDPE sheathed (2.0 mm min wall), to AS/NZS 1429.1 and TfNSW Standards T HR EL 20001 ST.
Approved for	Applications in accordance with T HR EL 20001 ST

Conditions

Approved:

Date: 02/07/2014

Neal Hook

Lead Electrical Engineer