



Product Type Approval Certificate

Full

This certificate is issued to:

Supplier name and address:	Raychem (TE Connectivity) Unit 2, No 3 Corella Close, Berkeley Vale NSW 2261
-----------------------------------	---

In respect of:

Manufacturer:	Raychem (TE Connectivity)
Place of manufacture:	Unit 2, No 3 Corella Close, Berkeley Vale NSW 2261
Product description:	Raychem ESD-5712-AU-04/20 – Termination for 33 kV screened single core XLPE insulated cables 500-630 mm ²
Use approved for:	Termination for 33 kV screened single core XLPE insulated cables 500-630 mm ²
Conditions of approval:	Termination kit shall be installed by staff that are Accredited Cable Jointers in accordance with Sydney Trains document PR-D-78701 <i>Personnel Certifications – Electrical</i> , and trained by TE Connectivity in accordance with the requirements of EP 20 00 03 01 SP
Limitations:	NA

Evaluating rail transport operator

Name:	Terry Niemeier
Position:	Lead Electrical Engineer, Asset Standards Authority, Transport for NSW
Signature:	<i>T Niemeier</i>
Date:	21/04/2020

Product approval pack reference number: fA1278532