

Product Type Approval Certificate

Restricted

This certificate is issued to:

Supplier name and address:	Wilson Transformers 310 Springvale Road, Glen Waverly, Victoria 3150, Australia
-----------------------------------	--

In respect of:

Manufacturer:	Wilson Transformers
Place of manufacture:	310 Springvale Road, Glen Waverly, Victoria 3150, Australia
Product description:	Power transformer, 66/33kV, YNyn0, 20MVA, ONAN, 66kV & 33kV can be configured for aerial or cable connection, with OLTC.
Use approved for:	Use on the RailCorp 66kV and 33kV network.
Conditions of approval:	Type approval is valid for the power transformer as detailed on the following set of general drawings EL0500335 – EL0500351 (all revision A).
Limitations:	Future procurement of this transformer would require engineering assurance for compliance with an ASA standard and consultation with the Lead Electrical Engineer, ASA.

Evaluating rail transport operator

Name:	Chris Lilly
Position:	A/Lead Electrical Engineer, Asset Standards Authority, Transport for NSW
Signature:	<i>C.Lilly</i>
Date:	26 th July, 2019

Product approval pack reference number: qA609664