

Product Type Approval Certificate

Full

This certificate is issued to:

Supplier name and address:	TE Connectivity Australia Pty. Ltd. Suite 501, Level 5/3 Thomas Holt Dr, Macquarie Park NSW 2113, Australia
-----------------------------------	---

In respect of:

Manufacturer:	Tyco Electronics Raychem GmbH
Place of manufacture:	Finsinger 1 Feld 85521 Ottobrunn, Germany
Product description:	Installation instruction manual: Raychem ESD-8817-AU-7/24 – Size Transition Joints for Screened 1-Core to 3-Core Plastic Insulated Cables, 11kV Kit detail: MXSU-3331-1C-T2 Drawing number: EL0263329
Use approved for:	11kV cables, as per T HR EL 20005 ST (TS 03752), T HR EL 20004 ST (TS 03751), and T HR EL 20010 ST (TS 03757).
Conditions of approval:	Transition joints shall be installed by staff that are Accredited Cable Jointers in accordance with Sydney Trains document PR-D- 78701 Personnel Certifications – Electrical, and trained by TE Connectivity in accordance with the requirements of T HR EL 20010 ST (TS 03757).
Limitations:	N/A

Evaluating rail transport operator

Name:	Lidija Dumbaloska
Position:	Director Energy Networks & Systems, Asset Management Branch, Transport for NSW
Signature:	<i>L. Dumbaloska</i>
Date:	24/09/2024

Independent safety assessor

Name:	
Position:	
Signature:	
Date:	

Independent technical reviewer

Name:	
Position:	
Signature:	
Date:	

Product approval pack reference number: fA17090682