

<b>Asset Standards Authority (internal use only)</b>	
<b>Product information pack reference</b>	fA745704

PTA EL141/2018

## Product Type Approval Certificate

This certificate is issued to:

<b>Supplier:</b>	Raychem (TE Connectivity)
	Unit 2, No 3 Corella Close, Berkeley Vale NSW 2261

In respect of:

<b>Manufacturer:</b>	Raychem (TE Connectivity)
<b>Place of manufacture:</b>	Unit 2, No 3 Corella Close, Berkeley Vale NSW 2261
<b>Product description:</b>	Raychem ESD-4870-AU-2/18 – Termination for 1.5 kV 1-core polymeric insulated cables with and without insulation screen and composite sheath, 240 mm <sup>2</sup> – 400 mm <sup>2</sup>
<b>Use approved for:</b>	Applications in accordance with EP 20 00 03 01 SP
<b>Product information pack reference</b>	A7045464 (objective reference)
<b>Conditions of approval:</b>	Termination kit shall be installed by staff that are Accredited Cable Jointers in accordance with Sydney Trains document PR-D-78701 <i>Personnel Certifications – Electrical</i> , and trained by TE Connectivity in accordance with the requirements of EP 20 00 03 01 SP
<b>Limitations:</b>	Nil
<b>Notes / Comments:</b>	Nil

## Approval

<b>ASA Lead Engineer:</b>	Neal Hook, Asset Standards Authority
<b>Position:</b>	Lead Electrical Engineer
<b>Contact details:</b>	Neal.Hook@transport.nsw.gov.au
<b>Signature:</b>	
<b>Date:</b>	

*[Fill this section only if independent safety assessor is engaged, otherwise mention N/A]*

<b>Independent safety assessor:</b>	N/A
<b>Position:</b>	
<b>Contact details:</b>	
<b>Signature:</b>	
<b>Date:</b>	