



**TS 04955.2:1.0**

ESB 004

**Standard**

# **Services, Systems and Equipment**

## **Part 2: Stations**

Issue date: 31 August 2022

Effective date: 31 August 2022

## Disclaimer

This document has been prepared by Transport for NSW (TfNSW) specifically for its own use and is also available for use by NSW public transport agencies for transport assets.

Any third parties considering use of this document should obtain their own independent professional advice about the appropriateness of using this document and the accuracy of its contents. TfNSW disclaims all responsibility and liability arising whether directly or indirectly out of or in connection with the contents or use of this document.

TfNSW makes no warranty or representation in relation to the accuracy, currency or adequacy of this document or that the document is fit for purpose.

The inclusion of any third party material in this document, does not represent an endorsement by TfNSW of any third party product or service.

For queries regarding this document, please email Transport for NSW Asset Management Branch at [standards@transport.nsw.gov.au](mailto:standards@transport.nsw.gov.au) or visit [www.transport.nsw.gov.au](http://www.transport.nsw.gov.au)

## Document information

**Owner:** Director Interchanges and Buildings  
Asset Management  
Safety, Environment and Regulation

**Mode:** Heavy rail and metro

**Discipline:** Interchanges and buildings

## Document history

Revision	Effective date	Summary of changes
1.0	31/08/2022	Supersedes ESB 004, v1.1. First issue as TS 04955.2:1.0. Version number recommenced in line with new designation.

## Preface

This document supersedes ESB 004 *Station Services and Systems, v1.1* and is a first issue as TS 04955.2:1.0 *Services, Systems and Equipment – Part 2: Stations*.

This document forms part of TS 04955 *series of documents relating to systems, services and equipment*.

This document should be read in conjunction with TS 04955.1.

Transport facilities are considered an increased risk environment with constraints that may not be present in other buildings. Specific requirements are therefore necessary to ensure the safety, functionality and desired technical characteristics of the services and systems installations present within a transport facility.

This standard outlines the requirements and guiding principles associated with services, systems and equipment for train stations and metro stations. This standard contains functional, technical and operational requirements.

## Table of contents

<b>1</b>	<b>Scope</b> .....	<b>6</b>
<b>2</b>	<b>Application</b> .....	<b>6</b>
<b>3</b>	<b>Referenced documents</b> .....	<b>6</b>
<b>4</b>	<b>Terms, definitions and abbreviations</b> .....	<b>7</b>
<b>5</b>	<b>General requirements</b> .....	<b>7</b>
<b>6</b>	<b>Services</b> .....	<b>7</b>
6.1	Heating, ventilation and air-conditioning .....	8
6.2	Escalators and lifts .....	10
6.3	Electrical .....	10
6.4	Lighting .....	10
6.5	Hydraulic .....	11
6.6	Fire .....	11
<b>7</b>	<b>Systems</b> .....	<b>11</b>
7.1	Electronic security .....	11
7.2	Ticketing system .....	12
7.3	Customer information systems .....	13
<b>8</b>	<b>Infrastructure</b> .....	<b>13</b>
8.1	Infrastructure integrated with station .....	13
8.2	Infrastructure not integrated with station .....	13
<b>9</b>	<b>Maintenance and upgrade strategies</b> .....	<b>13</b>
<b>10</b>	<b>Assurance</b> .....	<b>14</b>

# 1 Scope

This document sets the requirements for services and systems at train stations and metro stations (referred to as stations in this document) across NSW, to facilitate compliance with legislative and TfNSW requirements.

This standard covers services, systems, infrastructure and equipment in stations.

Services and systems provided in stations depend on the size and importance of a station, and the functional and operational environment. Stations may include partially enclosed or fully enclosed structures or buildings of different sizes.

Refer to TS 04955.1 for detailed list of services, systems, infrastructure and equipment in TfNSW facilities, including stations.

# 2 Application

This standard applies to TAOs and staff of TfNSW involved in the provision of services and systems for stations.

This standard applies to new installations, and upgrades, additions and changes to existing installations.

This standard applies to the planning, design, construction, operation, maintenance, and decommissioning stages of services and systems life cycle.

This standard should be read in conjunction with TS 04955.1.

# 3 Referenced documents

The following documents are cited in the text. For dated references, only the cited edition applies. For undated references, the latest edition of the referenced document applies.

## **Transport for NSW standards**

T HR SS 80001 ST *Infrastructure Lighting*

T HR SS 80003 ST *Infrastructure Emergency Lighting*

T MU SY 10001 ST *Public Transport Closed Circuit Television (CCTV) Functional Requirements Standard* (This document is not publicly available. To obtain access email [standards@transport.nsw.gov.au](mailto:standards@transport.nsw.gov.au))

T MU SY 20001 ST *Surface Transport Fixed Infrastructure Physical Security Standard* (This document is not publicly available. To obtain access email [standards@transport.nsw.gov.au](mailto:standards@transport.nsw.gov.au))

TS 00008.2 *Fire and Life Safety – Part 2: Stations*

TS 03954 *Low Voltage Electrical Installations*

TS 04955.1 *Services, Systems and Equipment – Part 1: Principles*

TS 04955.3 *Services, Systems & Equipment – Part 3: Lifts*

TS 04955.4 *Services, Systems and Equipment – Part 4: Escalators and Moving Walks*

## Legislation

*Rail Safety National Law 2012 (NSW)*

*Transport Administration Act 1988*

## 4 Terms, definitions and abbreviations

The following terms, definitions and abbreviations apply in this document:

**CCTV** closed circuit television

**metro station** a place to get on and off metro services

**repair** the work to restore the installation to safe and sound working condition after a deterioration or damage occurred

**SFAIRP** so far as is reasonably practicable

**station** includes train station and metro station

**train station** a place to get on and off trains

**TfNSW** Transport for NSW

**VAM** visual aid monitor

## 5 General requirements

The provision of services, systems, and equipment in stations shall comply with TS 04955.1.

Services, systems and equipment in stations shall facilitate safety, SFAIRP. Requirements in *Rail Safety National Law 2012 (NSW)* and the *Transport Administration Act 1988* apply.

## 6 Services

All station services and systems installations shall observe safe separation distances to high voltage overhead line and traction structures, and related safety precautions. Services, such as services crossing a station concourse, or a pedestrian bridge should not run above high voltage overhead lines.

Above-ground metallic components of services, systems and equipment shall observe 2.5 m clearance from any metallic structure that can become electrified.

Maintenance access to all services and systems installations shall be available at all times. Station services and systems shall not be located in areas where access can only be achieved by securing possession, for example, under platform copings. All equipment shall be accessible from behind the platform yellow line.

Services and systems installations shall be mounted such that they do not to impede access paths, circulation routes or create a hazard to station users or interfere with access to any equipment.

## **6.1 Heating, ventilation and air-conditioning**

Heating, ventilation and air-conditioning shall support normal and emergency operation of a station, and include smoke management and smoke exhaust, designed, constructed and operated to comply with location-specific fire and life safety strategy and the resultant fire engineered solution.

### **6.1.1 Occupied spaces**

Concourse and platform areas are large spaces where adequate air-conditioning may be difficult to achieve. Additional contaminant sources from the trains (such as brake dust) are often present at stations. Airflow effects from the trains moving into and out of the station shall be taken into account while designing station air-conditioning, and ventilation.

Natural ventilation shall be prioritised over mechanical ventilation where reasonably practicable, to ventilate concourses, platforms and similar transit spaces. For stations open to outdoor ambient conditions, architectural features such as awnings and shades may be used to achieve acceptable comfort conditions.

Natural ventilation shall aim to maintain the temperature of ambient conditions. The temperature shall not exceed a maximum of 5°C above ambient temperature.

Air-conditioning to public spaces of above ground and underground stations shall be provided where ventilation alone is not able to ensure acceptable standards of passenger comfort.

In underground and enclosed stations, the concourse cavern and each of the platform levels shall be equipped with separate air-conditioning and ventilation systems, with each system capable of maintaining design conditions during normal operation and fire emergency. This is not required for stations where the concourse cavern and the platforms are in the same space cavity.

Air-conditioning and ventilation system supply and exhaust points shall be arranged to provide sufficient air movement to avoid capture and stagnation of warm air in the platform space.

Canopies and shading structures shall be capable of restricting at least 80% of summer solar radiation to improve the thermal comfort of sheltered occupants.



## 6.1.2 Track exhaust and smoke extract

The following shall be evaluated to determine the provision of track exhaust systems at underground and enclosed stations:

- tunnel ventilation interfacing requirements
- fire engineered smoke exhaust requirements
- train brake dust
- heat dissipation (for example, from trains, air conditioning plant and so on)
- station environmental conditions, air conditioning and ventilation requirements
- mitigation of trackside air infiltration into the station environment.

Where track exhaust is provided, the under-platform exhaust system shall be designed to prevent dissemination of brake dust.

The over track exhaust system shall be designed as part of the ventilation arrangement to provide the following:

- exhaust to ensure comfortable conditions for platform users during day-to-day operation
- smoke extract to ensure tenable conditions during a fire emergency, for the length of time required for emergency evacuation of the station and adjacent tunnel.

The station air-conditioning and ventilation system shall be integrated with adjacent tunnel and track ventilation systems to ensure that all relevant systems are designed, constructed, and operated as a coordinated, wholistic solution.

All trackway exhaust system exhaust discharge points shall be located greater than 12 m from any air intakes including, but not limited to, the following:

- station entrances
- openings from platforms to concourses
- air-conditioning and ventilation fire air intakes
- tunnel draught relief shaft outlet/intakes
- tunnel ventilation fan intakes.

## 6.1.3 Tunnel smoke extract

The tunnel smoke extract system shall control the propagation of smoke developing from a rolling stock fire at a specific release rate. This is to ensure tenable conditions during a fire emergency, for the length of time required for emergency evacuation of the tunnel.

The smoke extract system shall control smoke and heat to allow for the safe evacuation of tunnel occupants. Ventilation equipment and installation that is necessary for control of smoke shall be capable of continuous operation as required by the location-specific fire engineering solution.

All tunnel exhaust system exhaust discharge points shall be located greater than 12 m from any surrounding air intakes including the following:

- station entrances
- openings from platforms to concourses
- air-conditioning and ventilation fire air intakes
- tunnel draught relief shaft outlet/intakes
- tunnel ventilation fan intakes.

#### **6.1.4 Concourse exhaust and smoke extract**

The concourse exhaust and smoke extract system shall be designed as part of the ventilation arrangement to provide the following:

- exhaust to ensure comfortable conditions for the users during day-to-day operation
- smoke extract to ensure tenable conditions during a fire emergency, for the length of time required for emergency evacuation of the station and adjacent tunnels.

#### **6.1.5 Exhaust and smoke extract for on-grade and open stations**

Exhaust and smoke extract systems may be provided for on-grade and open stations including elevated parts of the station and elevated platforms, depending on station design and configuration of station spaces.

### **6.2 Escalators and lifts**

Lift services, and escalators and moving walks in stations shall comply with TS 04955.3 and TS 04955.4, respectively.

### **6.3 Electrical**

Electrical services in stations shall comply with TS 03954.

### **6.4 Lighting**

Lighting services in stations shall comply with T HR SS 80001 ST.

Emergency lighting services in stations shall comply with T HR SS 80003 ST.

## 6.5 Hydraulic

Pipe for underground installations near 1500 V track should be non-metallic.

Where this is not avoidable, in-ground metallic pipes greater than 50 mm diameter shall be layered with a corrosion protection system such as Denso system or other similar proprietary system. Any metallic pipe serving a building or facility located near 1500 V dc structures shall be equipped with an isolating spool, installed in an approved location at the boundary of the rail corridor. All exposed metallic pipework shall be adequately bonded to earth to minimise the effects of stray current corrosion.

Platform drainage systems shall enable the platform to be drained centrally (that is, not towards the track) and to then discharge water to the stormwater drainage system. Ponding on platforms shall not be permitted.

Station or platform stormwater, or both, shall not drain to the track or into the track drainage in the adjacent rail corridor, at any time.

## 6.6 Fire

The risk of injury or fatality during normal rail operation, or in case of an adverse event such as an accident, collision or fire, shall be eliminated or minimised, SFAIRP. Requirements in *Rail Safety National Law 2012 (NSW)* apply.

The design, installation and operation of all station services and systems that serve passenger rail network facilities including stations, tunnels, and ancillary buildings shall identify and manage relevant risks and include appropriate mitigation measures that are compliant with asset fire life safety strategy for a particular location.

Fire and life safety services for stations and adjacent infrastructure, for example under ground stations, shall comply with TS 00008.2.

## 7 Systems

Security requirements for systems' cabling and routes shall comply with T MU SY 20001 ST.

### 7.1 Electronic security

#### 7.1.1 General

Rail security networks are integrated to provide 24/7 support and coordination to ensure a timely and efficient response to network infrastructure incidents.

The extent of electronic security installations that are required at a particular location shall be determined in response to a specific risk assessment prepared in collaboration with the operator

and maintainer and TfNSW security agencies. Refer to T MU SY 10001 ST and T MU SY 20001 ST for more information.

Station alarms shall be installed in accordance with T MU SY 20001 ST including remote monitoring through a centralised security monitoring centre.

### **7.1.2 Help Points**

Help points shall be integrated with the CCTV system that is compliant with T MU SY 20001 ST, to allow emergency communication.

### **7.1.3 CCTV**

The operator and maintainer undertakes CCTV surveillance in the course of its business activities for the following purposes:

- safety and security of staff and customers
- protection of property and other assets
- effective network operations and protection of public interest
- deterrence, prevention, reduction, investigation and prosecution of crime in areas monitored by CCTV
- provision of evidence to the police and authorised agencies.

In addition to security functions, where required by fire engineered solutions, CCTV cameras shall be installed in nominated locations to aid fire and life safety response. Refer to TS 00008.2 for further requirements.

### **7.1.4 Train guard visual access CCTV**

On station platforms with difficult or obstructed sightlines a locally positioned platform VAM shall be used as necessitated by platform physical layout. The VAM shall be used to provide feeds from CCTV cameras to facilitate visual aid to train guards.

### **7.1.5 Remote operation of toilet doors**

CCTV shall be installed to capture toilet entrances in accordance with T MU SY 10001 ST and to assist the operation of the unlocking of passenger toilets that are not within a direct line of sight of station staff, without them having to leave their post. For unmanned stations, operation from a remote location on the network should be enabled.

## **7.2 Ticketing system**

Ticketing system in stations shall comply with TS 04955.1.

## 7.3 Customer information systems

Refer to TS 04955.1 for requirements that apply to customer information systems in stations.

## 8 Infrastructure

Transport infrastructure systems extend network-wide to facilitate train operation and customer service.

### 8.1 Infrastructure integrated with station

Refer to TS 04955.1 for requirements relating to rail network infrastructure and public infrastructure that is integrated with stations.

### 8.2 Infrastructure not integrated with station

Rail network infrastructure systems that are passing through a station but are not connected to any of the station systems and services (for example, signalling installations) are not covered by this standard.

However, while some of the infrastructure systems are not required to be connected to any equipment on a particular station, they still require accommodation within the station spaces, utilising agreed and coordinated service routes.

The following are examples of rail-network-wide infrastructure that can pass through a station without necessarily being connected to station services or systems.

- track, including track geometry, track support, clearance limits and requirements
- civil, including bridges and civil structures, and related road and pedestrian structures, retaining walls, platform structures, overhead wiring support structures, tunnels, and track drainage
- signal, including signals and control systems, guards indicators, level crossings
- traction power, electrical HV, and LV power distribution systems that pass through but do not feed power to the station.

These infrastructure routes shall be coordinated with station architectural and structural features as well as station engineering systems and services.

## 9 Maintenance and upgrade strategies

All services, systems and equipment maintenance and upgrades shall comply with TS 04955.1. These strategies shall be applied within the context of a station environment and appropriate possession frameworks.

## 10 Assurance

All services, systems and equipment shall be assured in accordance with TS 04955.1.