



## Type Approval - Electrical

<b>Approval Number</b>	EL 00021
<b>Manufacturer</b>	Raychem (TE Connectivity)
<b>Manufacturing Plant</b>	Unit 2, No 3 Corella Close, Berkeley Vale NSW 2261
<b>Product Description</b>	Raychem ESD-6266-AU-11/13 – Outdoor Terminations for 72kV Single Core XLPE Insulated Cables with Lead Sheath and Copper Wire Screen Including DTS.  Insulation diameter range: 38-55mm  Outer Sheath max diameter: 70mm
<b>Approved for</b>	Outdoor termination of 66 kV single core cables complying with T HR EL 20001 ST
<b>Conditions</b>	Termination kit shall be installed by staff that are accredited and trained in accordance with the requirements of EP 20 00 03 01 SP

Approved:

Date: 12/12/2014

---

Neal Hook

Lead Electrical Engineer