

Type Approval - Electrical

Approval Number	EL 00037
Manufacturer	Nexans (Yanggu) New Rihui Cable Co. Ltd
Manufacturing Plant	No. 14, Xihu, Yanggu, Liaocheng City, Shandong, China
Product Description	Nexans Olex Marketing Code XHZP15RB001 – 1 Conductor 16 mm ² stranded compacted plain annealed copper, semi-conductive conductor screen (0.3 mm min wall), 3.8/6.6 kV TR-XLPE insulated (2.5 mm nom wall), PVC (5V-90) Sheathed (1.8 mm nom wall), to AS/NZS 1429.1 where applicable & TfNSW Standards T HR EL 20001 ST & T HR EL 20002 ST.
Approved for	Applications in accordance with T HR EL 20002 ST
Conditions	Approvals apply to ASA evaluated material grades only – details held by ASA. Changes to insulation and sheathing material grades for use in this cable item require resubmission to ASA for technical evaluation.

Approved: Neal Hook

Date: 19/7/16

Lead Electrical Engineer