



Type Approval - Electrical

| | |
|----------------------------|--|
| Approval Number | EL 00038 |
| Manufacturer | Nexans (Yanggu) New Rihui Cable Co. Ltd |
| Manufacturing Plant | No. 14, Xihu, Yanggu, Liaocheng City, Shandong, China |
| Product Description | Nexans Olex Marketing Code XHZP17RB001 – 1 Conductor 25 mm ² stranded compacted plain annealed copper, semi-conductive conductor screen (0.3 mm min wall), 3.8/6.6 kV TR-XLPE insulated (2.5 mm nom wall), PVC (5V-90) Sheathed (1.8 mm nom wall), to AS/NZS 1429.1 where applicable & TfNSW Standards T HR EL 20001 ST & T HR EL 20002 ST. |
| Approved for | Applications in accordance with T HR EL 20002 ST |
| Conditions | Approvals apply to ASA evaluated material grades only – details held by ASA. Changes to insulation and sheathing material grades for use in this cable item require resubmission to ASA for technical evaluation. |

Approved: Neal Hook

Date: 19/7/16

Lead Electrical Engineer