



## Type Approval - Electrical

<b>Approval Number</b>	EL 00125
<b>Manufacturer</b>	Raychem (TE Connectivity)
<b>Manufacturing Plant</b>	Unit 2, No 3 Corella Close, Berkeley Vale NSW 2261
<b>Product Description</b>	Raychem ESD-5999-AU-1/17 – Joint for 33 kV 1-core to 3-core screened polymeric insulated cables, 150 – 300 mm <sup>2</sup> , without DTS fibres
<b>Approved for</b>	Joint for 33 kV 1-core to 3-core screened polymeric insulated cables, 150 – 300 mm <sup>2</sup> , without DTS fibres, complying with T HR EL 20001 ST
<b>Conditions</b>	Joint kit shall be installed by staff that are Accredited Cable Jointers in accordance with Sydney Trains document PR-D-78701 <i>Personnel Certifications – Electrical</i> , and trained by TE Connectivity in accordance with the requirements of EP 20 00 03 01 SP sections 4.2 and 5.5

Approved:

Date:

\_\_\_\_\_  
Neal Hook

Lead Electrical Engineer

\_\_\_\_\_