



## Type Approval - Electrical

<b>Approval Number</b>	EL 00003
<b>Manufacturer</b>	Olex Australia Pty Limited
<b>Manufacturing Plant</b>	207 Sunshine Road, Tottenham, Victoria, Australia
<b>Product Description</b>	Olex Marketing Code XHNP28QJ001 – 1 Conductor 400 mm <sup>2</sup> stranded compacted plain annealed copper, semi-conductive conductor screen (0.3 mm min wall), 3.8/6.6 kV TR-XLPE insulated (3.0mm nom wall), Strippolex insulation screen (0.6 mm min wall), copper wire screened (area 90 mm <sup>2</sup> min suitable for 13.5 kA for 1 sec fault level), PVC (5V-90) sheathed (2.0 mm min wall), HDPE sheathed (2.0 mm min wall), to AS/NZS 1429.1 and TfNSW Standards T HR EL 20001 ST and T HR EL 20002 ST.
<b>Approved for</b>	Applications in accordance with T HR EL 20002 ST

### Conditions

Approved:

Date: 02/07/2014

---

Neal Hook

Lead Electrical Engineer