



PTA EL 110/2017

Product Type Approval Certificate

This certificate is issued to:

Supplier:	Transformers Manufacturing Company Pty Ltd
	19 Ewing St, Brunswick, Victoria 3056

In respect of:

Manufacturer:	Transformers Manufacturing Company Pty Ltd
Place of manufacture:	19 Ewing St, Brunswick, Victoria 3056
Product description:	Power Transformer, 66/11kV, 2MVA, ONAN, complete with OLTC, 66kV & 11kV cable connected, in accordance with ASA standard T HR EL 02001 SP (version 1.0).
Use approved for:	Use on the RailCorp 66kV and 11kV distribution networks.
Conditions of approval:	Type approval is valid for the power transformer as detailed on the following set of general drawings (all rev A) EL0560119 - EL0560125.
Limitations:	N/A
Comments:	Contact the Lead Electrical Engineer, ASA for type approval requirements of transformers with a different MVA rating.

Approval

ASA Lead Engineer:	Chris Lilly, Asset Standards Authority
Position:	A/Lead Electrical Engineer
Contact details:	chris.lilly@transport.nsw.gov.au
Signature:	
Date:	9 th January 2019

Independent safety assessor:	N/A
Position:	
Contact details:	
Signature:	
Date:	