

Asset Standards Authority (internal use only)		
Product information pack reference number	fA1150365	

PTA EL159/2019

## **Product Type Approval Certificate**

This certificate is issued to:

Supplier:	Raychem (TE Connectivity)
	Unit 2, No 3 Corella Close, Berkeley Vale NSW 2261

## In respect of:

Manufacturer:	Raychem (TE Connectivity)
Place of manufacture:	Unit 2, No 3 Corella Close, Berkeley Vale NSW 2261
Product description:	Raychem ESD-7937-AU-3/19 – Size transition joint for 33kV screened single core XLPE insulated cables 185/400mm² to 500mm², in which a joint for DTS fibre optics is not required
Use approved for:	Joint for 33 kV single core XLPE insulated cables 185/400mm <sup>2</sup> to 500mm <sup>2</sup> , complying with T HR EL 20001 ST
Conditions of approval:	Joint kit shall be installed by staff that are Accredited Cable Jointers in accordance with Sydney Trains document PR-D-78701 Personnel Certifications – Electrical, and trained by TE Connectivity in accordance with the requirements of EP 20 00 03 01 SP
Limitations:	Nil
Comments:	Nil

## **Approval**

ASA Lead Engineer:	Terry Niemeier
Position:	Lead Electrical Engineer
Contact details:	Terry.Niemeier@transport.nsw.gov.au
Signature:	
Date:	

[Fill this section only if independent safety assessor is engaged, otherwise mention N/A]

Independent safety assessor:	
Position:	N/A
Contact details:	
Signature:	
Date:	