

# **Product Type Approval Certificate**

## Full

#### This certificate is issued to:

| Supplier name and | Raychem (TE Connectivity)                          |  |
|-------------------|--|--|
| address:          | Unit 2, No 3 Corella Close, Berkeley Vale NSW 2261 |  |

### In respect of:

| Manufacturer:           | Raychem (TE Connectivity)  |
|-------------------------|--|
| Place of manufacture:   | Unit 2, No 3 Corella Close, Berkeley Vale NSW 2261   |
| Product description:    | Raychem ESD-6116-AU-8/20 – Joint for 33 kV screened three core XLPE insulated cables 150-300 mm <sup>2</sup>   |
| Use approved for:       | Joint for 33 kV screened three core XLPE insulated cables 150-<br>300 mm <sup>2</sup>  |
| Conditions of approval: | Termination kit shall be installed by staff that are Accredited Cable Jointers in accordance with Sydney Trains document PR-D-78701 Personnel Certifications – Electrical, and trained by TE Connectivity in accordance with the requirements of EP 20 00 03 01 SP |
| Limitations:            | NA   |

# **Evaluating rail transport operator**

| Name:      | Terry Niemeier   |
|------------|--|
| Position:  | Lead Electrical Engineer, Asset Standards Authority, Transport for NSW |
| Signature: | T Niemeier   |
| Date:      | 05/08/2020   |

Product approval pack reference number: fA1313363